



BV LCIE
CHINA
Number

N° 2266AS01ASCQ44108

ATTESTATION of conformity with European Directives

Product: **Miniature Circuit Breaker**
Reference **EKM3-63**
Issued to **ZHEJIANG ETEK ELECTRICAL TECHNOLOGY CO.,LTD**
Address **NO.288 Wei 17th Road, Yueqing Economic Development Zone Yueqing,
Wenzhou, Zhejiang Province P.R.China**
Manufacturer **ZHEJIANG ETEK ELECTRICAL TECHNOLOGY CO.,LTD**
Uc: 230V~ or 240V~(1P);400V~ or 415V~(2P/3P/4P)
Selectivity category: A
Ie:1A;2A;3A;4A;5A;6A;8A;10A;13A;16A;20A;25A;32A;40A;50A;63A
50/60Hz
Ics=Icu=6kA
Ui= 500V
Technical characteristics **Uimp=6kV**
IP20 for front cover
Pollution degree: 2
Reference temperature: 30°C
Distance for metal screen:
Back:0mm Front:0mm; Top:50mm Botton:50mm; Left:0mm
Right:0mm(values declared by client)

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

<i>Standards</i>	<i>Report number</i>	<i>Report date</i>
EN 60947-2:2017+A1:2020 EN 60947-1:2007 + A1:2011 + A2:2014	B210095	09/12/2021

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product

The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), January 21st, 2022.

Charlie CHEN
Product Line Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA

必维欧亚电气技术咨询服务(上海)有
限公司

Version 3/2016.02.19

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email: contact@cn.bureauveritas.com