



Reference No. SE-S-2200247

Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs)

EKL7-40

Type designation:

Certificate holder:	Zhejiang ETEK Electrical technology Co., Ltd. No. 288 Wei 17th Road, Yueqing Economic Development Zone, Yueqing, Wenzhou, Zhejiang Province, P.R. China
The product complies the standard(s):	EN 61009-1:2012+A1+A2+A11+A12
Date of expiry:	01 March, 2027
EU Directive informa	According to the principle of presumption of conformity, this certificate constitutes support for an EU Declaration of Conformity to the Low Voltage Directive 2014/35/EU.
Additional information	in Appendix
Certification Body:	Intertek Semko AB, Product Certification Place: Kista - Stockholm
Signed:	Date: 01 March, 2022 Leif Mattsson

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Intertek Semko AB Page 1 of 2



APPENDIX:

Reference No. SE-S-2200247

Technical Data:

Type designation EKL7-40 Rated voltage (V) $230/240V \sim$

Rated current (A) 6, 10, 16, 20, 25, 32, 40A

Rated Residual Operating

Current (mA) 10, 30, 100, 300mA

Frequency (Hz) 50/60Hz
Poles No. 2P(1P+N)
Trademark

Test Report211201156SHA-001Product informationB-&C-type, type-A&-AC

Icn= Ics= 6000A, IΔm= 3000A, Energy limiting class 3

Manufacturing Sites: ZHEJIANG ETEK Electrical technology Co., Ltd.

No. 288 Wei 17th Road, Yueqing Economic Development Zone

Yueging, Wenzhou, Zhejiang Province, P.R. China

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

Safety related parts of the user instructions shall be written in a language acceptable to the country where the product is to be used.

Certification Body: Intertek Semko AB, Product Certification Place: Kista - Stockholm

Signed: Date: 01 March, 2022

Leif Mattsson

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Intertek Semko AB Page 2 of 2