

Zertifikat
mit überwachter Konformität

Certificate
of surveyed conformity



Zertifikat Nr. *Certificate No.*
J 50483849

Blatt *Sheet*
0001

Ihr Zeichen <i>Client Reference</i>	Unser Zeichen <i>Our Reference</i>	Ausstellungsdatum	<i>Date of Issue</i>
Z.Y.	01-SSC-50208429 004	09.11.2020	(day/mo/yr)

Genehmigungsinhaber <i>License Holder</i>	Fertigungsstätte <i>Manufacturing Plant</i>
Zhejiang ETEK Electrical Technology Co., Ltd. NO.288 Wei 17th Road, Yueqing Economic Development Zone, Yueqing, Wenzhou Zhejiang P.R. China	040-0002071162

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
EN 60269-6:2011
EN 60269-1:2007+A1+A2

Zertifiziertes Produkt (Geräteidentifikation) <i>Certified Product (Product Identification)</i>	Lizenzentgelte - Einheit <i>License Fee - Unit</i>
--	---

(Low-voltage Fuse for PV System)

Fuse-link Type Designation	: EKFL15D14L	5
Rated Voltage	: DC 1500V	
Rated Current	: 8A; 10A; 12A; 15A; 16A; 20A; 25A; 30A; 32A; 35A; 40A; 45A and 50A	
Rated Breaking Capacity:	20kA	
Breaking Range	: gPV	
Rated Power Dissipation:	no more than 6,1W at 0,7In no more than 13,6W at In	
Size	: 14mm*85mm	
Arc Voltage Limits	: 5000V (peak value)	

5

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.
This certificate is based on our Testing and Certification Regulation. The product fulfills above mentioned requirements, the production is subject to surveillance.

Zertifizierungsstelle

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com

Fax: +49 221 806-3935 http://www.tuv.com/safety



Kenny Shi

Zhejiang ETEK Electrical Technology
Co., Ltd.
Zhao Yun

Date : 09.11.2020
Our ref. : SSC 01
Your ref.: Z.Y.

NO.288 Wei 17th Road,
Yueqing Economic Development Zone,
Yueqing, Wenzhou
Zhejiang
P.R. China

Ref : J Certificate of Surveyed Conformity

Type of Equipment : Low-voltage Fuse for PV System
Model Designation : See Certificate
Certificate No. : J 50483849 0001
Report No. : 50208429 004

Dear Zhao Yun,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.


Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body


Kenny Shi

cc: ZHEJIANG CHIFENG ELECTRIC

Enclosure

证书的详细资料请登陆www.tuvdotcom.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询